

TOWN OF TOWN OF EMMITSBURG, MD DePaul Street Waterline Pre-Bid Agenda

ADDENDUM NO. 7

This Addendum shall be incorporated into and form a part of the Contract Documents it shall modify the original Bidding Documents dated January 5, 2024, as noted below. All bids shall be based on this Addendum, in accordance with the bidding documents. Bidder must acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of ONE (1) pages.

- 1. Per Addendum #5 Q&A #8, the new water main is to be push on joints. Does each push on joint require a field lok gasket?
 - No. Standard joints are acceptable.

END OF ADDENDUM NO.7